



# 令和元年12月 騒音・振動測定値報告



工場内配置図



測定項目	規制基準値	12/4(水)		12/11(水)		12/18(水)		12/25(水)	
		10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10
騒音L05 dB	85.0	62.6	59.5	61.8	59.7	61.0	60.6	61.5	65.7
振動L10 dB	75.0	44.4	39.3	45.2	38.8	38.4	39.0	40.4	40.6