




令和2年3月 騒音・振動測定値報告



工場内配置図



測定項目	規制基準値	3/4(水)		3/11(水)		3/18(水)		3/25(水)	
		10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10
騒音L05 dB	85.0	62.0	62.7	64.6	61.8	62.7	62.4	62.3	66.0
振動L10 dB	75.0	37.9	36.0	40.8	38.6	40.1	39.5	39.0	39.8