




令和3年4月 騒音・振動測定値報告



工場内配置図



測定項目	規制基準値	4/7(水)		4/14(水)		4/21(水)		4/28(水)	
		10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10
騒音L05 dB	85.0	61.9	62.9	62.8	61.8	61.4	62.7	62.5	66.0
振動L10 dB	75.0	41.9	42.8	42.6	43.1	41.6	43.1	39.0	38.5