



令和3年9月 騒音・振動測定値報告



工場内配置図



測定項目	規制基準値	9/1(水)		9/8(水)		9/15(水)		9/22(水)		9/29(水)	
		10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10
騒音L05 dB	85.0	67.6	67.2	61.9	61.3	68.9	65.6	62.6	62.1	62.6	61.0
振動L10 dB	75.0	29.7	28.5	30.2	31.0	31.3	29.6	29.9	31.9	29.7	29.2