



令和3年11月 騒音・振動測定値報告



工場内配置図



測定項目	規制基準値	11/3(水)		11/10(水)		11/17(水)		11/24(水)	
		10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10
騒音L05 dB	85.0	58.2	56.6	61.4	61.5	70.4	61.0	63.5	61.5
振動L10 dB	75.0	21.5	20.6	31.7	30.1	36.4	30.7	31.0	31.2