



令和4年2月 騒音・振動測定値報告



工場内配置図



測定項目	規制基準値	2/2(水)		2/9(水)		2/16(水)		2/23(水)	
		10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10
騒音L05 dB	85.0	61.4	63.4	62.3	63.3	62.1	62.4	59.9	59.2
振動L10 dB	75.0	40.6	39.2	40.2	37.5	40.7	36.9	36.0	31.5