



# 令和5年2月 騒音・振動測定値報告



工場内配置図



測定項目	規制基準値	2/1(水)		2/8(水)		2/15(水)		2/20竣工に伴い 騒音振動測定器を撤去	
		10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10	10:00 ~ 10:10	15:00 ~ 15:10
騒音L05 dB	85.0	67.1	63.4	60.8	60.5	78.6	63.5	—	—
振動L10 dB	75.0	48.9	49.5	50.9	50.2	53.8	50.0	—	—